FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 10-03-2015**

TEST REPORT ON WET MIX MACADAM MIX
(GRADATION TEST)

Sub: To conduct Gradation test on Wet Mix Macadam (WMM) Mix.
{Project*:Improvements and Asphalting to M E S School roads in Ward No.09 of Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 07-03-2015

Sample supplied to lab by: Sri.M.Srinivasa Murthy, Contractor, Bangalore.

Report required for: Assistant Executive Engineer, Vidyaranyapura Sub-Division. BBMP, Bangalore.

TEST RESULTS

1. Gradation Test:

TABLE 1.1

Sieve Size mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Specified Limits as per MoRTH Specifications, IV Revision-2001
53.00	**100.00**	100
45.00	**96.00**	95-100
26.50	**---**	-
22.40	**72.10**	60-80
11.20	**46.30**	40-60
4.75	**39.00**	25-40
2.36	**21.00**	15-30
0.600	**15.90**	8-22
0.075	**4.90**	0-8

*As Furnished by Client

The Results relate only to the items tested

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

10/3/2015

Dr. MANJESH .L
ME (Civil Engg) Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 10-04-2015**

TEST REPORT ON BITUMINOUS MIXES
(BITUMEN EXTRACTION TEST & GRADATION TEST)

Sub: Testing of Bitumen Premix Sample (Semi Dense Bituminous Concrete-SDBC).
{Project*:Improvements and Asphalting to M E S School roads in Ward No.09 of Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 09-04-2015

Sample supplied to lab by: Sri.M.Srinivasa Murthy, Contractor, Bangalore.

Report required for: Assistant Executive Engineer, Vidyaranyapura Sub-Division. BBMP, Bangalore.

TEST RESULTS:

7. The bitumen content obtained after subjecting the sample for Bitumen Extraction test = **5.04 %**
8. **Gradation Test** :

Sieve Size, mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Gradation requirement as per Table 500-15 of MORTH Specifications-2001 (Grading – 2)
13.2	**100**	100
9.5	**95.80**	90—100
4.75	**44.00**	35—51
2.36	**37.10**	24—39
1.18	**23.00**	15—30
0.3	**16.30**	09—19
0.075	**4.40**	03—08

* As furnished by Client.
The Results relate only to the items tested.

10/04/2015

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg) Ph D MISTE MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e-mail. manjeshl@yahoo.com